

February 15, 2017

To Whom It May Concern:

Smith Valves are designed according to API 602/ASME B16.34 and are tested according to the 2014 edition of API 624 – Type Testing of Rising Stem Valves Equipped with Graphite Packing for Fugitive Emissions which is certified in accordance with API 622 – Type Testing of Process Valve Packing for Fugitive Emissions. All tested and untested valves are designed to the same quality requirements. The characteristics of the valve that affect seal ring performance, (e.g., stem design, stem motion, tolerances, seating arrangement, and stem, packing, design, and construction) are the same or essentially equivalent as tested and untested valves. The temperature and pressure rating of the tested valves are at least as high as the untested valves of the same material.

Based on the enclosed certificates, Yarmouth Research and Technology is certifying the valves and packing did not emit greater than 100 ppm screening value and on average emitted less than 50 ppm screening value. Smith Valves guarantees that the valves listed in the table below will not exceed 100 ppm external leakage under normal operating conditions provided the body bolting and stem packing gland nut torques are properly maintained. This statement is based on the customer following suggested stem gland nut torques in Smith Valves IOM.

Valve Type	Class	Size
	150	
0.475	300	
GATE (THD/SWE/RF)	600	1/4" - 2"
(IIIB/GWL/RI)	800	
	1500	

Thank you,

Mani Prakash Pilla, P.E. Engineering Manager

"Type Testing of Rising Stem Valves Equipped with Graphite Packing for Fugitive Emissions"

Performed for

The Newdell Company

http://www.smithvalves.com

3/4 NPS Class 800 Gate Valve THDxTHD, BB, A105, API Trim 8 Product Code: 0800OOOOO75

Project Number: 214128
Test Start Date: August 4, 2014

Performed by

YARMOUTH RESEARCH AND TECHNOLOGY, LLC

434 Walnut Hill Road North Yarmouth, ME 04097 USA (207) 829-5359

API 624 TEST CERTIFICATE

Certificate Number: 214128C		Test Start Date	: 4-Aug-14
		Test End Date	: 7-Aug-14

,	
Customer: The Newdell Company	
Web Address: www.smithvalves.com	
Manufacturer Location: 13750 Hollister Rd Houst	on, TX 77086
Valve Information	
Valve Description: 3/4", Class 800, THDxTHD	, BB, A105, API Trim 8
Product Code: 0800OOOO075	Valve Size: 3/4"
Assembly Drawing No.: 0800OOO#	Valve Pressure Class: 800
Body Material: A105	Valve Type: Gate
Stem Material: 410 NACE	Stem Motion: Rising
API/ASME Design Standards: ASME B16.3	34, API 602
Packing Description: Two end rings = Garlock 13	303-FEP, Three center rings = GL 409
Body/Bonnet Seal Description: Bolted	

Test Results			
Test Specification: A	PI 624 Fi	irst Edition: 2014	
Max. Allowable Stem Seal Leakage:	100	PPMv Methane	
Number of Mechanical Cycles:	310		
High Temperature:	500	deg. F	
Test Pressure:	600	psig	
Did valve pass test requirements?	YES		

Valve Selected by: Manufacturer

Qualifications of similar valves according to para. 10 of test standard				
Size Range: NPS 1 and smaller			Pressure Class Range:	up to and including Class 800

Certified By

Customer Information

March & Whitelink



"Type Testing of Rising Stem Valves Equipped with Graphite Packing for Fugitive Emissions"

Performed for

The Newdell Company

http://www.smithvalves.com

1-1/2 NPS Class 800 Gate Valve THDxTHD, BB, A105, API Trim 8 Product Code: 080000000150

Project Number: 214128
Test Start Date: November 13, 2014

Performed by

YARMOUTH RESEARCH AND TECHNOLOGY, LLC

434 Walnut Hill Road North Yarmouth, ME 04097 USA (207) 829-5359

API 624 TEST CERTIFICATE

Certificate Number: 214128E		Test Start Date.	13-Nov-14
		Test End Date	18-Nov-14

•		
Customer: The Newdell Company		
Web Address: www.smithvalves.com		
Manufacturer Location: 13750 Hollister Rd Houst	on, TX 77086	
Value Information		
Valve Description: 1-1/2", Class 800, THDxTH	ID, BB, A105, API Trim 8	
Product Code: 0800OOOO150	Valve Size: 1-1/2"	
Assembly Drawing No.: 0800OOO#	Valve Pressure Class: 800	
Body Material: A105	Valve Type: Gate	
Stem Material: 410 NACE	Stem Motion: Rising	
API/ASME Design Standards: ASME B16.3	34, API 602	
Packing Description: Two end rings = Garlock 1303-FEP, Three center rings = 409GL		
Body/Bonnet Seal Description: Bolted		
Valve Selected by: Manufacture	er	

Test Results			
Test Specification: A	PI 624 Fi	irst Edition: 2014	
Max. Allowable Stem Seal Leakage:	100	PPMv Methane	
Number of Mechanical Cycles:	310		
High Temperature:	500	deg. F	
Test Pressure:	600	psig	
Did valve pass test requirements?	YES		

Qualifications of similar valves according to para. 10			g to para. 10 of test standa	rd
	Size Range:	NPS 1 1/4 - 2 1/2	Pressure Class Range:	up to and including Class 800

Certified By

Customer Information

Hart & their link



"Type Testing of Rising Stem Valves Equipped with Graphite Packing for Fugitive Emissions"

Performed for

The Newdell Company

http://www.smithvalves.com

3/4 inch Class 1500 Gate Valve THDxTHD, BB, A105, API Trim 8 Product Code: 1500OOOOO075

Project Number: 214128
Test Start Date: May 22, 2014

Performed by

YARMOUTH RESEARCH AND TECHNOLOGY, LLC

434 Walnut Hill Road North Yarmouth, ME 04097 USA (207) 829-5359

API 624 TEST CERTIFICATE

Certificate Number: 214128A Test Start Date: 22-May-14
Test End Date: 25-May-14

Customer	Inform	ation
Customer		

Customer: The Newdell Company Web Address: www.smithvalves.com

Manufacturer Location: 13750 Hollister Rd Houston, TX 77086

Valve Information

Valve Description: 3/4 inch Class 1500 Gate Valve THDxTHD, BB, A105, API Trim 8

Product Code: 150000000075 Valve Size: 3/4"

Assembly Drawing No.: 15000000# Valve Pressure Class: 1500

Body Material: A105 Valve Type: Gate

Stem Material: 410 NACE Stem Motion: Rising

API/ASME Design Standards: ASME B16.34, API 602

Packing Description: Two end rings = Garlock 1303-FEP, Three center rings = GL 409

Body/Bonnet Seal Description: Bolted

Valve Selected by: Manufacturer

Test Results

Test Specification: API 624 First Edition: 2014				
Max. Allowable Stem Seal Leakage:	100	PPMv Methane		
Number of Mechanical Cycles:	310			
High Temperature:	500	deg. F		
Test Pressure:	600	psig		
Did valve pass test requirements?	YES			

ı	Quali	fications o	f similar v	alves according	to para, 10 c	of test standard
п	Quuii		i griirraa C	arces according	to para. It c	ij icoi oiuniaana

,	,	 	•	
Size Range:	1 inch and smaller	Pressure	e Class Range:	1500

Certified By

Mart & Warelink



"Type Testing of Rising Stem Valves Equipped with Graphite Packing for Fugitive Emissions"

Performed for

The Newdell Company

http://www.smithvalves.com

1-1/2 inch Class 1500 Gate Valve THDxTHD, BB, A105, API Trim 8 Product Code: 1500OOOOO150

Project Number: 214128
Test Start Date: May 28, 2014

Performed by

YARMOUTH RESEARCH AND TECHNOLOGY, LLC

434 Walnut Hill Road North Yarmouth, ME 04097 USA (207) 829-5359

API 624 TEST CERTIFICATE

Certificate Number:	214128B	Test Start Date:	28-May-14
		Test End Date:	2-Jun-14

Customer	Injormation
	Ο .

Customer: The Newdell Company Web Address: www.smithvalves.com

Manufacturer Location: 13750 Hollister Rd Houston, TX 77086

Valve Information

Valve Description: 1-1/2 inch Class 1500 Gate Valve THDxTHD, BB, A105, API Trim 8

Product Code: 15000000150 Valve Size: 1-1/2"

Assembly Drawing No.: 15000000# Valve Pressure Class: 1500

Body Material: A105 Valve Type: Gate

Stem Material: 410 NACE Stem Motion: Rising

API/ASME Design Standards: ASME B16.34, API 602

Packing Description: Two end rings = Garlock 1303-FEP, Three center rings = GL 409

Body/Bonnet Seal Description: Bolted

Valve Selected by: Manufacturer

Test Results

Test Specification: API 624 First Edition: 2014

Max. Allowable Stem Seal Leakage: 100 PPMv Methane

Number of Mechanical Cycles: 310

High Temperature: 500 deg. F

Test Pressure: 600 psig

Did valve pass test requirements? YES

Size Range: NPS 1-1/4 through NPS 2-1/2 Pressure Class Range: 1500

Certified By

Hart & Whitelink





APPENDIX B

Fugitive Emission Test Report

API 624 1st Edition Standard

Performed for

The Newdell Company

2016

Smith 3/4" Class 1500 RF Gate Valve
Made Per ASME B16.34/API 602
Met Qualifications Set Forth In API 624 1st Edition Using
Garlock EVSP 9000 Packing w/1303 FEP End Rings

Work Order: 96989-1 Start Date: April 27, 2016 End Date: April 29, 2016

Performed by

United Valve, LLC

9916 Gulf Freeway Houston, TX77034 Phone: 713-944-9852 Fax: 713-944-5964

www.unitedvalve.com



API 624 Testing Summary

Customer: The NEWDELL Company **Test start date:** 04-27-2016

13750 Hollister Road **Test finish date:** 04-29-2016

Houston, TX 77086-1213

Work order: 96989-01

Packing information

Packing description Garlock EVSP 9000 w/1303 FEP End Rings

Packing set Graphite, 6 split-ring set

Packing cross section 0.235 Inches

Test fixture United Valve Test Bench 5- #5

API 622 completion Yes, see Appendix B

Testing criteria

EPA maximum allowable leakage	100	PPM	
Test pressure (Ambient)	600	PSIG	
Test pressure (500°F)	600	PSIG	
Test media	99% Methane		
Recommended nut torque	180	In-Lbs	
Tested stem travel per stroke	0.78	Inches	
Cycling speed	33	Seconds per stroke	
Cycling rate	66	Seconds per cycle	

Results

Number mechanical cycles required	310
Number mechanical cycles completed	310
Number thermal cycles required	3
Number thermal cycles completed	3

Stem seal leakage (PPMv)				Gland torque	
Static leakage		Dynamic leakage		In-Lbs	
Avg.	Max	Avg.	Max	Low	Max
2	6	2	4	146	180

Tested by:	SCHELL	Witnessed by:	N/A	
------------	--------	---------------	-----	--



Fugitive Emission Test Report

API 624 1st Edition Standard

Performed for

The Newdell Company

2016

Smith 1-1/2" Class 1500 RF Gate Valve
Made Per ASME B16.34/API 602
Met Qualifications Set Forth In API 624 1st Edition Using
Garlock EVSP 9000 Packing w/1303 FEP End Rings

Work Order: 97265-01 Start Date: May 17, 2016 End Date: May 20, 2016

Performed by

United Valve, LLC

9916 Gulf Freeway Houston, TX77034 Phone: 713-944-9852 Fax: 713-944-5964

www.unitedvalve.com



API 624 Testing Summary

Customer: The Newdell Company
13750 Hollister Road
Test start date: 05/17/2016
Test finish date: 05/20/2016

Houston, TX 77086-1213

Work order: 97265

Packing information

Packing descriptionGarlock EVSP 9000 w/1303 FEP End RingsPacking setGarlock 9000 EVSP w/1303 end rings

Packing cross section 3/8 Inches

Test fixture 1-1/2" 1500 Smith A105 Gate Valve RF

API 622 completion Yes, see appendix B

Testing criteria

EPA maximum allowable leakage	100	PPM	
Test pressure (Ambient)	600	PSIG	
Test pressure (500°F)	600	PSIG	
Test media	99% M	99% Methane	
Recommended gland nut torque	540-560	In-Lbs	
Tested stem travel per stroke	1.67	Inches	
Cycling speed	71	Seconds per stroke	
Cycling rate	142	Seconds per cycle	

Results

Number mechanical cycles required	310
Number mechanical cycles completed	310
Number thermal cycles required	3
Number thermal cycles completed	3

Stem seal leakage (PPMv)			Gland torque		
Static	Static leakage Dynamic leakage		Choose One		
Avg.	Max	Avg.	Max	Low	Max
2	7	2	4	310	560

Tested b	y: Schell	Witnessed by:	N/A